

LICENCE HOLDER:

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS:

No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

Scope of Certification: The CSI PAS-Mark Scheme is a Type 5, Product Certification Scheme, and is in conformance with the stated requirements of, ISO/IEC 17065. CSI are accredited as conforming to the requirements of, ISO/IEC 17065 by the Joint Accreditation System of Australia and New Zealand — commonly known as JASANZ, a signatory member of the International Accreditation Forum (IAF) Multilateral Arrangement (MLA).

The Licensee named above, agrees to comply with the following Certification Solutions International Pty. Ltd., (CSI) scheme documents,

- 1) PAS_001 The Product Assessment Scheme – Rules and Requirements,
- 2) PAS_002 Terms, Conditions and Appeals Process,
- 3) PAS_003 Use of the Certificate & Trademark Logo.

The Product Assessment Scheme documents, (PAS_001, 002 & 003), are available on the CSI website at,
<https://www.csi-certification.com/assessment-certification>

This Certificate of Conformity and associated Product Compliance Schedule/s, issued by CSI are to confirm that the relevant requirements of the product standard as claimed by the licence holder, have been assessed by CSI as being met. The responsibility for the product performance and its fitness for the intended use remain with the certificate licence holder. This certification is not transferable.

Certification Solutions International Pty Ltd, conduct annual surveillance during the term of the certification on the licence holder/manufacturer to monitor their ongoing capability to consistently produce products in compliance with:

AS 2047:2014 Windows and external glazed doors in buildings

CSi Licence Number:
Certification Issue Date:
Certification Expiry Date:
CSi Schedule Number:

7708
20 July 2025
19 July 2026
CSi Lic No. 7676-2025-07-C1-R0

Certification Review Date:
Next Annual Review Date:
CSi Database ID Number:

4 June 2025
15 June 2026
1000413

PAS-Mark


Azma Khan
Managing Director



<https://register.jasanz.org/>

<https://iaf.nu/en/mla-mark/>

The current validity of this document may be checked online at either the JASANZ register, <https://register.jasanz.org/certified-organisations> or by scanning the QR Code or contacting admin@csi-certification.com

*This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.
For details of manufacture refer to the licensee.*

LICENCE HOLDER:

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS:

No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

Scope of Certification: The CSI PAS-Mark Scheme is a Type 5, Product Certification Scheme, and is in conformance with the stated requirements of, ISO/IEC 17065. CSI are accredited as conforming to the requirements of, ISO/IEC 17065 by the Joint Accreditation System of Australia and New Zealand — commonly known as JASANZ, a signatory member of the International Accreditation Forum (IAF) Multilateral Arrangement (MLA).

The Licensee named above, agrees to comply with the following Certification Solutions International Pty. Ltd., (CSI) scheme documents,

- 1) PAS_001 The Product Assessment Scheme – Rules and Requirements,
- 2) PAS_002 Terms, Conditions and Appeals Process,
- 3) PAS_003 Use of the Certificate & Trademark Logo.

The Product Assessment Scheme documents, (PAS_001, 002 & 003), are available on the CSI website at,
<https://www.csi-certification.com/assessment-certification>

This Certificate of Conformity and associated Product Compliance Schedule/s, issued by CSI are to confirm that the relevant requirements of the product standard as claimed by the licence holder, have been assessed by CSI as being met. The responsibility for the product performance and its fitness for the intended use remain with the certificate licence holder. This certification is not transferable.

Certification Solutions International Pty Ltd, conduct annual surveillance during the term of the certification on the licence holder/manufacturer to monitor their ongoing capability to consistently produce products in compliance with:


SNZ TS 4211:2022 Specification for the classification of windows

CSi Licence Number:
Certification Issue Date:
Certification Expiry Date:
CSi Schedule Number:

7708
20 July 2025
19 July 2026
CSi Lic No. 7676-2025-07-C2-R0

Certification Review Date:
Next Annual Review Date:
CSi Database ID Number:

4 June 2025
15 June 2026
1000413


Azma Khan
Managing Director



<https://register.jasanz.org/>

<https://iaf.nu/en/mla-mark/>

The current validity of this document may be checked online at either the JASANZ register, <https://register.jasanz.org/certified-organisations> or by scanning the QR Code or contacting admin@csi-certification.com

*This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.
For details of manufacture refer to the licensee.*


PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSi Licence Number may be used.


AS 2047:2014 Windows and external glazed doors in buildings

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Infiltration Rating	Date of Endorsement
	MD150SD-02	MD150SD Sliding Door	1200 Pa Rating: N5 (General) N4 (Corner windows)	3000 Pa Rating: N5 (General) N4 (Corner windows)	No water penetration at: 0 Pa for 5 mins and 350Pa for 15 mins. Rating: N4, C2 (Exposed) N5, C3 (Non-exposed)	At +75Pa 0.65 L/s m² At -75Pa 0.92 L/s m² Rating: Low	26 June 2025 Test Report No. AZHK250619
			PASS	PASS	PASS	PASS	
Dimension of Window Frame:		2820 mm (Height) x 4020 mm (Width) x 151.6 mm (Thickness)					
Dimension of Window Sash:		Operable Sash 1: 2604 mm (Height) x 1260 mm (Width), Operable Sash 2: 2604 mm (Height) x 1260 mm (Width), Fixed Panel 1: 2604 mm (Height) x 1260 mm (Width)					
Frame Corner Construction Details:		Sliding Door: Screws; Frame: Screws.					
Hardware:		Model No: B152, Name: Double-chain hand-operated window opener, Supplier: ZHENJIAN; Model No: L1524-4, Name: pulley block, Supplier: QILUNBI					
Drainage:		Sizes: 30 mm (Width) × 6 mm (Height) Quantity: 9					
Gasket (between the sash and the frame)		Model No.: EPDM-EP1046/ EPDM-EP1047, Materials: EPDM, Supplier: MEIRUN Model No.: 5*5*5 Wool / 5*5*7 Wool, Materials: Wool, Supplier: LIJIALONG					
Thermal break:		None.					
Reinforcement:		Model No.: PU-FOAM, Materials: PU, Supplier: PINXIANG, Location: Applied to entire length of Transom Sil.					
1. This certification excludes, Section 7 installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSi Licence Number: 7708
Certification Issue Date: 20 July 2025
Certification Expiry Date: 19 July 2026
CSi Schedule Number: CSi Lic 7676-2025-07-S1-R0

Certification Review Date: 4 June 2025
Next Annual Review Date: 15 June 2026
CSi Database ID Number: 1000413


Azma Khan
Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
This document is the property of CSi and must be returned to CSi upon its request. This document may only be reproduced in its entirety.


PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSI Licence Number may be used.


AS 2047:2014 Windows and external glazed doors in buildings

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Infiltration Rating	Date of Endorsement
	MD100AW-02	MD100AW Awning Window	1200 Pa Rating: N5 (General) N4 (Corner windows)	3000 Pa Rating: N5 (General) N4 (Corner windows)	No water penetration at: 0 Pa for 5 mins and 600Pa for 15 mins. Rating: N6, C4 (Exposed)	At +75Pa 0.009 L/s m² At -75Pa 0.023 L/s m² Rating: Low	26 June 2025 Test Report No. AZHK250601
			PASS	PASS	PASS	PASS	
Dimension of Window Frame:		2640mm (Height) x 2530mm (Width) x 100 mm (Thickness)					
Dimension of Window Sash:		Operable Sash 1: 1352 mm (Height) x 1090mm (Width), Fixed Panel 1: 2504 mm (Height) x 1170 mm (Width), Fixed Panel 2: 1005 mm (Height) x 1170mm (Width)					
Frame Corner Construction Details:		Awning Window: Corner Stake and Screw. Frame: Screw.					
Hardware:		Model No: Doric DN450, Name: Hand window opener, Quantity: 1 pc, Supplier: Doric					
Drainage:		Sizes: 30 mm (Width) × 6 mm (Height) Quantity: 4					
Gasket (between the sash and the frame)		Model No.: EP1043 / EP1044, Materials: EPDM, Supplier: MEIRUN Model No: 5*5*10 Wool, Material: Wool, Supplier: BINXIANGJIAOYE					
Thermal break:		None.					
Reinforcement:		Model No.: PU-FOAM, Materials: PU, Supplier: PINXIANG, Location: Full Length of Awning Frame Transom, Full Length of Awning Frame Mullion					
1. This certification excludes, Section 7 installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSI Licence Number: 7708
Certification Issue Date: 20 July 2025
Certification Expiry Date: 19 July 2026
CSI Schedule Number: CSI Lic 7676-2025-07-S2-R0

Certification Review Date: 4 June 2025
Next Annual Review Date: 15 June 2026
CSI Database ID Number: 1000413


Azma Khan
Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.


PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSI Licence Number may be used.


AS 2047:2014 Windows and external glazed doors in buildings

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Infiltration Rating	Date of Endorsement
	80 Series Bi-Fold	5 Sash 80 Series Bi-Fold	1300 Pa Rating: N5 (General) N4 (Corner windows)	2000 Pa Rating: N4 (General) N3 (Corner windows)	No water penetration at: 0 Pa for 5 mins and 150Pa for 15 mins. Rating: N3, C1 (Non-exposed)	At +75Pa 4.13 L/s m² At -75Pa 5.62 L/s m² Rating: High	12/07/2022 Test Report No. AZT0345.22
			PASS	PASS	PASS	PASS	
Dimension of Window Frame:		2400 mm (Height) × 4250 mm (Width)					
Dimension of Window Sash:		Sash 1: 2325 mm (Height) x 820 mm (Width), Sash 2: 2325 mm (Height) x 820 mm (Width), Sash 3: 2325 mm (Height) * 820 mm (Width) Sash 4: 2325 mm (Height) x 820 mm (Width), Sash 5: 2325 mm (Height) x 820 mm (Width)					
Frame Corner Construction Details:		Screw.					
Hardware:		ASWS -BI01					
Drainage:		Yes(Details not specified in the test report).					
Gasket (between the sash and the frame)		Rubber(Details not specified in the test report).					
Thermal break:		Not specified in the test report					
Reinforcement:		Not specified in the test report.					
1. This certification excludes, Section 7 installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSI Licence Number: 7708
Certification Issue Date: 20 July 2025
Certification Expiry Date: 19 July 2026
CSI Schedule Number: CSI Lic 7676-2025-07-S3-R0

Certification Review Date: 4 June 2025
Next Annual Review Date: 15 June 2026
CSI Database ID Number: 1000413


Azma Khan
Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.


PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSI Licence Number may be used.


AS 2047:2014 Windows and external glazed doors in buildings

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Infiltration Rating	Date of Endorsement
	ACG-100 Double Hung Window	ACG-100 Double Hung Window	800 Pa Rating: N4 (General) N3 (Corner windows) PASS	2000 Pa Rating: N4 (General) N3 (Corner windows) PASS	No water penetration at: 300 Pa. (Water penetration occurred at the joint between operable sash bottom rail and frame after spraying for 2 mins at 450Pa.) Rating: N5 (Non-exposed) N4 (Exposed) PASS	At +75Pa 4.02 L/s m ² At -75Pa 4.35 L/s m ² Rating: High PASS	10 March 2022 Test Report No. 220223081GZU-003
Dimension of Window Frame:		1206 mm (Width) x 2060mm (Height) x 118 mm (Thickness)					
Dimension of Window Sash:		Operable Sash: 1230mm (Width) x 1030 mm (Height) x 50mm (Thickness); Fixed Sash: 1230mm (Width) x 1030 mm (Height) x 50mm (Thickness)					
Frame Corner Construction Details:		Mechanically assembled: Screw: ST4.2*25 & Aluminium Connector: 50*50*30*T4.					
Hardware:		Specify type: Double Hung, Model: UXC100, Supplier: CALDWELL.					
Drainage:		Sizes: 40 mm (Width) × 8 mm (Height) Quantity: 3					
Gasket (between the sash and the frame)		Materials: EPDM, Supplier: HAIDA;					
Thermal break:		Model: C14.8, Material: PA66F, Supplier: Yile					
Reinforcement:		None.					
1. This certification excludes, Section 7 installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSI Licence Number: **7708**
 Certification Issue Date: 20 July 2025
 Certification Expiry Date: 19 July 2026
 CSI Schedule Number: CSI Lic 7676-2025-07-S4-R0

Certification Review Date: 4 June 2025
 Next Annual Review Date: 15 June 2026
 CSI Database ID Number: 1000413


 Azma Khan
 Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.


PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSI Licence Number may be used.


AS 2047:2014 Windows and external glazed doors in buildings

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Infiltration Rating	Date of Endorsement
	ACG100 -100 Sliding Door	ACG100 - 100 Sliding Door	600 Pa Rating: N3 (General)	2000 Pa Rating: N4 (General)	No water penetration at: 200 Pa. (Water kept splashing into interior from the joint of the aluminum profile and door sash at sliding sash side when spraying at 300Pa.) Rating: N4 (Non-exposed) N3 (Exposed)	At +75Pa 1.24 L/s m ² At -75Pa 1.45 L/s m ² Rating: High	2022/4/7
			PASS	PASS	PASS	PASS	Test Report No. 220223081GZU-004
Dimension of Window Frame:		5400 mm (Width) x 2650mm (Height) x 118 mm (Thickness)					
Dimension of Window Sash:		Operable Sash: Operable Sash: 1350(Width) x 2550mm (Height) x 40mm(Thickness), QTY: 2; Fixed Sash:1350 (Width) x 2550mm(Height) x 40mm(Thickness), QTY: 2;					
Frame Corner Construction Details:		Mechanically assembled: Screw: ST4.2 * 35.					
Hardware:		Model: ZCDG421-1500 & ZTLS1320 & ZMHL4410, Supplier: KINLONG.					
Drainage:		Sizes: 40 mm (Width) × 8 mm (Height) Quantity: 15					
Gasket (between the sash and the frame)		Materials: EPDM, Supplier: HAIDA;					
Thermal break:		Model: C14.8, Material: PA66F, Supplier: Yile					
Reinforcement:		None.					
1. This certification excludes, Section 7 installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSI Licence Number: **7708**
 Certification Issue Date: 20 July 2025
 Certification Expiry Date: 19 July 2026
 CSI Schedule Number: CSI Lic 7676-2025-07-S5-R0

Certification Review Date: 4 June 2025
 Next Annual Review Date: 15 June 2026
 CSI Database ID Number: 1000413


 Azma Khan
 Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.


PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSI Licence Number may be used.


AS 2047:2014 Windows and external glazed doors in buildings

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Infiltration Rating	Date of Endorsement
	ACG100 -220 Sliding Door	ACG100 - 220 Sliding Door	800 Pa Rating: N4 (General)	2000 Pa Rating: N4 (General)	No water penetration at: 300 Pa. (Water overflowed into interior from the glide path when spraying at 450 Pa.) Rating: N5 (Non-exposed) N4 (Exposed)	At +75Pa 4.48 L/s m ² At -75Pa 4.22 L/s m ² Rating: High	2022/4/7 Test Report No. 220223081GZU-005
			PASS	PASS	PASS	PASS	
Dimension of Window Frame:		4050 mm (Width) x 2650mm (Height) x 238 mm (Thickness)					
Dimension of Window Sash:		Operable Sash: 1350 (Width) x 2550 mm (Height) x 40mm (Thickness), QTY: 2; Fixed Sash: 1350 (Width) x 2550 mm (Height) x 40mm (Thickness).					
Frame Corner Construction Details:		Mechanically assembled: Screw: ST4.2 * 35.					
Hardware:		Model: DS2130, Supplier: Doric.					
Drainage:		Sizes: 40 mm (Width) × 8 mm (Height) Quantity: 11					
Gasket (between the sash and the frame)		Materials: EPDM, Supplier: HAIDA;					
Thermal break:		Model: C14.8, Material: PA66F, Supplier: Yile					
Reinforcement:		None.					
1. This certification excludes, Section 7 installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSI Licence Number: **7708**
 Certification Issue Date: 20 July 2025
 Certification Expiry Date: 19 July 2026
 CSI Schedule Number: CSI Lic 7676-2025-07-S6-R0

Certification Review Date: 4 June 2025
 Next Annual Review Date: 15 June 2026
 CSI Database ID Number: 1000413


 Azma Khan
 Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.


PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSI Licence Number may be used.


AS 2047:2014 Windows and external glazed doors in buildings

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Infiltration Rating	Date of Endorsement
	ACG140-220 Sliding Door	ACG140-220 Sliding Door	800 Pa Rating: N4 (General)	2000 Pa Rating: N4 (General)	No water penetration at: 450 Pa. Rating: N6 (Non-exposed) N5 (Exposed)	At +75Pa 4.42 L/s m ² At -75Pa 4.69 L/s m ² Rating: High	2022/4/8
			PASS	PASS	PASS	PASS	Test Report No. 220223081GZU-006
Dimension of Window Frame:		9000mm (Width) x3100mm (Height) x 230 mm (Thickness)					
Dimension of Window Sash:		Operable Sash: 3000 (Width) x 2350 m (Height) x 55mm (Thickness), QTY: 3.					
Frame Corner Construction Details:		Mechanically assembled: Screw: ST4.2 * 35.					
Hardware:		Model: ZCDG421-1500 & ZTLS1320 & ZMHL4410, Supplier: KINLONG.					
Drainage:		Sizes: 40 mm (Width) × 8 mm (Height) Quantity: 15					
Gasket (between the sash and the frame)		Materials: EPDM, Supplier: HAIDA;					
Thermal break:		Model: C14.8, Material: PA66F, Supplier: Yile					
Reinforcement:		None.					
1. This certification excludes, Section 7 installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSI Licence Number: **7708**
 Certification Issue Date: 20 July 2025
 Certification Expiry Date: 19 July 2026
 CSI Schedule Number: CSI Lic 7676-2025-07-S7-R0

Certification Review Date: 4 June 2025
 Next Annual Review Date: 15 June 2026
 CSI Database ID Number: 1000413


 Azma Khan
 Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
 This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.

PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSI Licence Number may be used.


AS 2047:2014 Windows and external glazed doors in buildings

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Infiltration Rating	Date of Endorsement
	BA150	BA150 Swing Door	1170 Pa Rating: N4 (General)	2000 Pa Rating: N4 (General)	No water penetration at: 200 Pa. Rating: N4, C2 (Non-exposed) N1, N2 (Exposed)	At +75Pa 0.52 L/s m² At -75Pa 0.35 L/s m² Rating: Low	2020/11/9 Test Report No. QTM-2020-20-01
			PASS	PASS	PASS	PASS	
Dimension of Window Frame:		2574mm (Width) x2800mm (Height)					
Dimension of Window Sash:		Operable Sash: 1410 (Width), QTY: 1.					
Frame Corner Construction Details:		Mechanically assembled: Screw.					
Hardware:		Not specified in the test report.					
Drainage:		Not specified in the test report.					
Gasket (between the sash and the frame)		Not specified in the test report.					
Thermal break:		Not specified in the test report.					
Reinforcement:		Not specified in the test report.					
1. This certification excludes, Section 7 installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSI Licence Number: **7708**
 Certification Issue Date: 20 July 2025
 Certification Expiry Date: 19 July 2026
 CSI Schedule Number: CSI Lic 7676-2025-07-S8-R0

Certification Review Date: 4 June 2025
 Next Annual Review Date: 15 June 2026
 CSI Database ID Number: 1000413


 Azma Khan
 Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.


PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSI Licence Number may be used.

AS 2047:2014 Windows and external glazed doors in buildings

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Infiltration Rating	Date of Endorsement
	MA100AWHD-001	MA100 Hinged Door Plus Awning Window	800 Pa Rating: N4 (General)	2000 Pa Rating: N4 (General)	No water penetration at: 600 Pa. Rating: N6,C4 (Exposed)	At +75Pa 0.03 L/s m² At -75Pa 0.03 L/s m² Rating: Low	2024/8/26 Test Report No. AZHK240708
			PASS	PASS	PASS	PASS	
Dimension of Window Frame:		2480mm (Width) x 2500mm (Height) x 100mm (Thickness)					
Dimension of Window Sash:		Sash 1: 1175mm (Width) x 2400mm (Height) x 50mm (Thickness), Sash 2: 1175mm (Width) x 1150mm (Height) x 50mm (Thickness)					
Frame Corner Construction Details:		Mechanically assembled: Screw.					
Hardware:		Model No: TWS130(KINLONG), Name: Door Hinge, Quantity: 4 pcs; Model No: ZMGS1730(KINLONG), Name: Door Handle, Quantity: 1 set Model No: ZMSB4511/I(KINLONG), Name: Multipoint Door Lock (3 Points), Quantity: 1 set; Model No: ZKILA35B35(KINLONG), Name: Door Cylinder, Quantity: 1 set, Supplier: KINLONG Model No: DN450, Name: Window Lock, Type: Chainwinder, Quantity: 1 set, Supplier: Doric					
Drainage:		Sizes: 30 mm (Width) × 6 mm (Height) Quantity: 6					
Gasket (between the sash and the frame)		Model No.: 6x13, Size: 6mm x 13mm, Material: EPDM, Supplier: MEIRUN					
Thermal break:		Not specified in the test report.					
Reinforcement:		ST7.5x80 stainless steel screw					
1. This certification excludes, Section 7 installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSI Licence Number: **7708**
 Certification Issue Date: 20 July 2025
 Certification Expiry Date: 19 July 2026
 CSI Schedule Number: CSI Lic 7676-2025-07-S9-R0

Certification Review Date: 4 June 2025
 Next Annual Review Date: 15 June 2026
 CSI Database ID Number: 1000413


Azma Khan
 Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.


PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSI Licence Number may be used.

AS 2047:2014 Windows and external glazed doors in buildings

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Infiltration Rating	Date of Endorsement
	MA100SW-001	MA100 Sliding Window	800 Pa Rating: N4 (General)	2000 Pa Rating: N4 (General)	No water penetration at: 300 Pa. Rating: N4 (Exposed) N5 (Non-exposed)	At +75Pa 0.79 L/s m² At -75Pa 0.79 L/s m² Rating: Low	2024/8/26 Test Report No. AZHK240709
			PASS	PASS	PASS	PASS	
Dimension of Window Frame:		2480mm (Width) x 2500mm (Height) x 100mm (Thickness)					
Dimension of Window Sash:		1195mm (Width) x 1880mm (Height)					
Frame Corner Construction Details:		Mechanically assembled: Screw.					
Hardware:		Model No: 15x21-4, Name: Window Roller, Quantity: 2 pcs, Supplier: KINLONG Model No.: ZTLS1510(HOPO), Name: Door Lock, Quantity: 1 set, Supplier: HOPO					
Drainage:		Sizes: 30 mm (Width) × 6 mm (Height) Quantity: 6					
Gasket (between the sash and the frame)		Model No.: 6x13, Size: 6mm x 13mm, Material: EPDM, Supplier: MEIRUN					
Thermal break:		Not specified in the test report.					
Reinforcement:		ST7.5x80 stainless steel screw					
1. This certification excludes, Section 7 installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSI Licence Number: **7708**
 Certification Issue Date: 20 July 2025
 Certification Expiry Date: 19 July 2026
 CSI Schedule Number: CSI Lic 7676-2025-07-S10-R0

Certification Review Date: 4 June 2025
 Next Annual Review Date: 15 June 2026
 CSI Database ID Number: 1000413


 Azma Khan
 Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.


PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSI Licence Number may be used.

AS 2047:2014 Windows and external glazed doors in buildings

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Infiltration Rating	Date of Endorsement
	MA100SD-001	MA100 Sliding Door	800 Pa Rating: N4 (General)	2000 Pa Rating: N4 (General)	No water penetration at: 300 Pa. Rating: N4 (Exposed) N5 (Non-exposed)	At +75Pa 0.84 L/s m² At -75Pa 0.89 L/s m² Rating: Low	2024/8/26 Test Report No. AZHK240707
			PASS	PASS	PASS	PASS	
Dimension of Window Frame:		2400mm (Width) x 2650mm (Height) x 100mm (Thickness)					
Dimension of Window Sash:		1195mm (Width) x 2530 mm (Height)					
Frame Corner Construction Details:		Mechanically assembled: Screw.					
Hardware:		Model No: 15x21-4, Name: Door Roller, Quantity: 2 pcs, Supplier: KINLONG Model No: ZTLS1510(HOPO), Name: Door Lock Set, Quantity: 1 set, Supplier: HOPO					
Drainage:		Sizes: 20 mm (Width) × 8 mm (Height) Quantity: 4					
Gasket (between the sash and the frame)		Model No.: 6x13, Size: 6mm x 13mm, Material: EPDM, Supplier: MEIRUN					
Thermal break:		Not specified in the test report.					
Reinforcement:		ST7.5x80 stainless steel screw					
1. This certification excludes, Section 7 installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSI Licence Number: 7708
Certification Issue Date: 20 July 2025
Certification Expiry Date: 19 July 2026
CSI Schedule Number: CSI Lic 7676-2025-07-S11-R0

Certification Review Date: 4 June 2025
Next Annual Review Date: 15 June 2026
CSI Database ID Number: 1000413


Azma Khan
 Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.


PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSI Licence Number may be used.


AS 2047:2014 Windows and external glazed doors in buildings

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Infiltration Rating	Date of Endorsement
	MC140-220 Sliding door	MC140-220 Sliding door	1200 Pa Rating: N5 (General)	3000 Pa Rating: N5 (General)	No water penetration at: 300 Pa. (Water overflowed beyond the innermost edge of sill frame when tested at 450Pa.) Rating: N4 (Exposed) N5 (Non-exposed)	At +75Pa 1.57 L/s m² At -75Pa 1.19 L/s m² Rating: High	2024/2/21
			PASS	PASS	PASS	PASS	Test Report No. 231211142GZC-001
Dimension of Window Frame:		6795 mm (Width) x 2980 m (Height) x 305.6 mm (Thickness)					
Dimension of Window Sash:		Operable Sash: 2300 mm (Width) × 2900 mm (Height) × 55 mm (Thickness), QTY: 2; Fixed Sash: 2300 mm (Width) × 2900 mm (Height) × 55 mm (Thickness); QTY: 1					
Frame Corner Construction Details:		Mechanically assembled: Glued & screwed (Screw: ST4.8*35)					
Hardware:		Lock Model: ZCDG421-1500, Roller Model: ZMHL4410, Supplier: KINLONG					
Drainage:		Sizes: 50 mm (Width) × 20 mm (Height) Quantity: 20					
Gasket (between the sash and the frame)		Not applicable.					
Thermal break:		Model: C14.8, C20, Material: PA66GF25 Nylon insulation strip, Supplier: Baiyun Yile.					
Reinforcement:		Not applicable.					
1. This certification excludes, Section 7 installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSI Licence Number: **7708**
 Certification Issue Date: 20 July 2025
 Certification Expiry Date: 19 July 2026
 CSI Schedule Number: CSI Lic 7676-2025-07-S12-R0

Certification Review Date: 4 June 2025
 Next Annual Review Date: 15 June 2026
 CSI Database ID Number: 1000413


Azma Khan
 Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.


PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSi Licence Number may be used.

SNZ TS 4211:2022 Specification for the classification of windows

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Permeability Rating	Date of Endorsement
	MC140-220 Sliding door	MC140-220 Sliding door	±1250 Pa Rating: H PASS	±3000 Pa Rating: H PASS	No water penetration at:300 Pa Rating: H PASS	At +75Pa 1.57 L/s·m²(test 1) At +75Pa 1.84 L/s·m²(test 2) At -75Pa 1.19 L/s·m²(test 1) At -75Pa 1.39 L/s·m²(test 2) At +150Pa 2.18 L/s·m²(test 1) At +150Pa 2.56 L/s·m²(test 2) At -150Pa 1.91 L/s·m²(test 1) At -150Pa 2.24 L/s·m²(test 2) Rating: Class 1 PASS	21 February 2024 Test Report No.: 231211142GZC-002
Dimension of Window Frame:		6795 mm (Width) x 2980 m (Height) x 305.6 mm (Thickness)					
Dimension of Window Sash:		Operable Sash: 2300 mm (Width) × 2900 mm (Height) × 55 mm (Thickness), QTY: 2; Fixed Sash: 2300 mm (Width) × 2900 mm (Height) × 55 mm (Thickness); QTY: 1					
Frame Corner Construction Details:		Mechanically assembled: Glued & screwed (Screw: ST4.8*35)					
Hardware:		Lock Model: ZCDG421-1500, Roller Model: ZMHL4410, Supplier: KINLONG					
Drainage:		Sizes: 50 mm (Width) × 20 mm (Height) Quantity: 20					
Gasket (between the sash and the frame):		Not applicable.					
Thermal break:		Model: C14.8, C20, Material: PA66GF25 Nylon insulation strip, Supplier: Baiyun Yile.					
Reinforcement:		Not applicable.					
1. This certification excludes installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSi Licence Number: **7708**
 Certification Issue Date: 20 July 2025
 Certification Expiry Date: 19 July 2026
 CSi Schedule Number: CSi Lic 7676-2025-07-S13-R0

Certification Review Date: 4 June 2025
 Next Annual Review Date: 15 June 2026
 CSi Database ID Number: 1000413


Azma Khan
 Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
 This document is the property of CSi and must be returned to CSi upon its request. This document may only be reproduced in its entirety.


PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSI Licence Number may be used.

SNZ TS 4211:2022 Specification for the classification of windows

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Permeability Rating	Date of Endorsement
	NZ125-FS	NZ125 Sliding Door & Awning Window	±600 Pa Rating: L	±2000 Pa Rating: VH	No water penetration at:300 Pa Rating: H	At +75Pa 0.03 L/s·m² At -75Pa 0.04 L/s·m² At +150Pa 0.12 L/s·m² At -150Pa 0.20 L/s·m² Rating: Class 4	10 October 2024 Test Report No.: AZHK240908
Dimension of Window Frame:			2650mm (Height) x 2350mm (Width) x 125mm (Thickness)				
Dimension of Window Sash:			2530mm (Height) x 1195mm (Width)				
Frame Corner Construction Details:			Mechanically assembled: Glued & screwed.				
Hardware:			Name: Door Roller, Model: 15*21-4, QTY: 2 pcs, Supplier: XUNCHEN; Name: Door Lock, Model: B152 "D" LOOK, Quantity: 1 set, Supplier: ZHENGQIAN; Name: Hanging Hardware Component, Model: PH502ES, Quantity: 1 set, Supplier: HPPO				
Drainage:			Sizes: 30 mm (Width) × 8 mm (Height) Quantity: 6				
Gasket (between the sash and the frame):			Model: 6*13, Material: EPDM, Supplier: MEIRUN;				
Thermal break:			Model: C14.8/C12, Material: PA66+25GF, Supplier: BAIYINYILE;				
Reinforcement:			ST7.5*80 stainless steel screw;				
1. This certification excludes installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSI Licence Number: 7708
Certification Issue Date: 20 July 2025
Certification Expiry Date: 19 July 2026
CSI Schedule Number:

Certification Review Date: 4 June 2025
Next Annual Review Date: 15 June 2026
CSI Database ID Number: 1000413

CSi Lic 7676-2025-07-S14-R0


Azma Khan
Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.

PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSI Licence Number may be used.


SNZ TS 4211:2022 Specification for the classification of windows

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Permeability Rating	Date of Endorsement
	Swing Door and Awning Window System	Swing Door and Awning Window System	±800 Pa Rating: Medium	±1500 Pa Rating: High	No water penetration at:300 Pa Rating: High	At +150Pa 0.892 L/s·m² At -150Pa 5.33 L/s·m² Rating: Non air conditioned	11 June 2024 Test Report No.: QTM-2024-30-01
			PASS	PASS	PASS	PASS	
Dimension of Window Frame:		3600 mm (Width) x 2900 m (Height)					
Dimension of Window Sash:		Operable Sash 1: 1255 mm (Width) × 1400 mm (Height), QTY: 1; Fixed Sash: 1255 mm (Width) × 1500 mm (Height), QTY: 1;					
Frame Corner Construction Details:		Mechanically assembled: Glued & screwed;					
Hardware:		Not specified in the test report.					
Drainage:		Not specified in the test report.					
Gasket (between the sash and the frame):		Not specified in the test report.					
Thermal break:		Not specified in the test report.					
Reinforcement:		Not specified in the test report.					
1. This certification excludes installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSI Licence Number: **7708**
 Certification Issue Date: 20 July 2025
 Certification Expiry Date: 19 July 2026
 CSI Schedule Number: CSI Lic 7676-2025-07-S15-R1

Certification Review Date: 4 June 2025
 Next Annual Review Date: 15 June 2026
 CSI Database ID Number: 1000413


 Azma Khan
 Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
 This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.


PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSI Licence Number may be used.

AS 2047:2014 Windows and external glazed doors in buildings

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Infiltration Rating	Date of Endorsement
	VA-100 Double Hinge Door	VA-100 Double Hinge Door	800 Pa Rating: N4 (General)	2000 Pa Rating: N4 (General)	No water penetration at: 150 Pa. (Water penetration occurred at the joint between sash bottom rail and frame after spraying for 2 minutes at 200Pa.) Rating: N3 (Non-exposed)	At +75Pa 2.14 L/s m² At -75Pa 2.10 L/s m² Rating: High	2023/4/27 Test Report No. 220223081GZU-007
			PASS	PASS	PASS	PASS	
Dimension of Window Frame:		2400mm (Width) x2650mm (Height) x 118mm (Thickness)					
Dimension of Window Sash:		Operable Sash: 1140 (Width) × 2559 mm (Height) × 50mm (Thickness), QTY: 2					
Frame Corner Construction Details:		Mechanically assembled: Screwed (Screw: ST4.2*35)					
Hardware:		Specify type: Aluminum alloy hinge, Model: T-MJ05 & MCX320 & T-CDQ301, Supplier: Kinlong.					
Drainage:		Sizes: 40 mm (Width) × 8 mm (Height) Quantity: 6					
Gasket (between the sash and the frame)		Material: EPDM, Supplier: haiDa;					
Thermal break:		Model: C32 and C14.8, Material: PA66F, Supplier: Yile					
Reinforcement:		Not applicable.					
1. This certification excludes, Section 7 installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSI Licence Number: **7708**
 Certification Issue Date: 20 July 2025
 Certification Expiry Date: 19 July 2026
 CSI Schedule Number: CSi Lic 7676-2025-07-S16-R0

Certification Review Date: 4 June 2025
 Next Annual Review Date: 15 June 2026
 CSi Database ID Number: 1000413


Azma Khan
 Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.


PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSI Licence Number may be used.

AS 2047:2014 Windows and external glazed doors in buildings

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Infiltration Rating	Date of Endorsement
	VA100 Tilt & Turn Window	VA100 Tilt & Turn Window	800 Pa Rating: N4 (General) N3 (Corner windows)	2000 Pa Rating: N4 (General) N3 (Corner windows)	No water penetration at: 200 Pa. (Water leaked continuously at the joint between operable sash and frame when spraying at 300Pa.) Rating: N3 (Exposed) N4 (Non-exposed)	At +75Pa 0.86 L/s m² At -75Pa 0.82 L/s m² Rating: Low	2022/3/10 Test Report No. 220223081GZU-002
			PASS	PASS	PASS	PASS	
Dimension of Window Frame:		2460 mm (Width) x2500mm (Height) x 118 mm (Thickness)					
Dimension of Window Sash:		Operable Sash: 1230mm (Width) x 1400 mm (Height) × x50mm (Thickness)					
Frame Corner Construction Details:		Mechanically assembled: Screw: ST4.2*25 & Aluminium Connector: 50*50*30*T4.					
Hardware:		Model: Z-NPD210, Supplier: KINLONG;					
Drainage:		Sizes: 40 mm (Width) × 8 mm (Height) Quantity:7					
Gasket (between the sash and the frame):		Material: EPDM, Supplier: HaiDa;					
Thermal break:		Model: C14.8, Material: PA66F Nylon insulation strip, Supplier: Baiyun Yile.					
Reinforcement:		Not applicable.					
1. This certification excludes, Section 7 installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSI Licence Number: **7708**
 Certification Issue Date: 20 July 2025
 Certification Expiry Date: 19 July 2026
 CSI Schedule Number: CSI Lic 7676-2025-07-S17-R0

Certification Review Date: 4 June 2025
 Next Annual Review Date: 15 June 2026
 CSI Database ID Number: 1000413


Azma Khan
 Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.


PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSI Licence Number may be used.


AS 2047:2014 Windows and external glazed doors in buildings

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Infiltration Rating	Date of Endorsement
	VAH100 Awning Window	VAH100 Awning Window	800 Pa Rating: N3 (General) N3 (Corner window)	2000 Pa Rating: N4 (General) N3 (Corner window)	No water penetration at: 200 Pa. (Water penetration was occurred at the sash frame below the window opener after spraying for 2 minutes at 300 Pa.) Rating: N3 (Exposed) N4 (Non-exposed)	At +75Pa 0.52 L/s m ² At -75Pa 0.98 L/s m ² Rating: Low	2022/3/10 Test Report No. 220223081GZU-001
Dimension of Window Frame:			2460 mm (Width) x2500mm (Height) x 118 mm (Thickness)				
Dimension of Window Sash:			Operable Sash: 1230 mm (Width) x 1400 mm (Height) x 50 mm (Thickness)				
Frame Corner Construction Details:			Mechanically assembled: Screw: ST4 . 2 * 2.5 & Aluminium Connector: 50*50*30*T4				
Hardware:			Double Chain Twin Winder Model: DN450; Supplier: Doric Friction Stay Model: FJ600A-16; Supplier: KINLONG				
Drainage:			Sizes: 40 mm (Width) × 8 mm (Height) Quantity: 7				
Gasket (between the sash and the frame)			Material: EPDM; Supplier: haiDa;				
Thermal break:			Model: C14.8, Material: PA66F Nylon insulation strip, Supplier: Baiyun Yile.				
Reinforcement:			Not applicable.				
1. This certification excludes, Section 7 installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSI Licence Number: **7708**
 Certification Issue Date: 20 July 2025
 Certification Expiry Date: 19 July 2026
 CSI Schedule Number: CSI Lic 7676-2025-07-S18-R0

Certification Review Date: 4 June 2025
 Next Annual Review Date: 15 June 2026
 CSI Database ID Number: 1000413


 Azma Khan
 Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.


PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSI Licence Number may be used.

AS 2047:2014 Windows and external glazed doors in buildings

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Infiltration Rating	Date of Endorsement
	MD150SD-FSSF	Aluminum Sliding Door	1200 Pa Rating: N5 (General) N4 (Corner window)	3000 Pa Rating: N5 (General) N4 (Corner window)	No water penetration at: 450Pa for 15 minutes. Rating: N5 (Exposed) N6 (Non-exposed)	At +75Pa 0.26 L/s m² At -75Pa 0.35 L/s m² Rating: Low	2025/8/7 Test Report No. AZHK250801
			PASS	PASS	PASS	PASS	
Dimension of Window Frame:		3290 mm (Height) x 5200 mm (Width) x 151.6mm (Thickness)					
Dimension of Window Sash:		Fixed Panel (Left): 2845 mm (Height) x 1300 mm (Width), Operable Sash (Left): 2845 mm (Height) x 1300 mm (Width) Operable Sash (Right): 2845 mm (Height) x 1300 mm (Width), Fixed Panel (Right): 2845 mm (Height) x 1300 mm (Width)					
Frame Corner Construction Details:		Mechanically assembled(see testing report for details).					
Hardware:		Name: Twiin Sliding Patio Door Lock, Model No.: DS3130, Quantity: 1 piece, Supplier: Doric Australia Pty Ltd Name: pulley block, Type: Sliding Door Roller, Model No.: L1524-8, Quantity: 4 pieces, Supplier: QILUNBI					
Drainage:		Size: (Width x Height) 30 mm x 6 mm, Spacing: 480 mm, Quantity: 11					
Gasket (between the sash and the frame)		Model No.: 5*5 Wool, Size: 5*5, Quantity: 2, Material: Wool, Supplier: LIJIALONG; Model No.: 5*7 Wool, Size: 5*7, Quantity: 2, Material: Wool, Supplier: LIJIALONG Model No.: EPDM-EP1046, EPDM-EP1047, Size: 23*16, Quantity: 4, Materials: EPDM, Supplier: MEIRUN					
Thermal break:		None.					
Reinforcement:		None.					
1. This certification excludes, Section 7 installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSI Licence Number: **7708**
 Certification Issue Date: 12 Sept. 2025
 Certification Expiry Date: 19 July 2026
 CSI Schedule Number: CSI Lic 7708-2025-09-S19-R0

Certification Review Date: 4 June 2025
 Next Annual Review Date: 15 June 2026
 CSI Database ID Number: 1000413


 Azma Khan
 Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
 This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.


PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSI Licence Number may be used.


SNZ TS 4211:2022 Specification for the classification of windows

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Permeability Rating	Date of Endorsement
	MC80BD-TH	Aluminium Bi-fold Door	Positive - 1600 Pa Negative - 1300 Pa Rating: VH PASS	±2000 Pa Rating: VH PASS	Positive - 404 Pa Rating: VH PASS	At +75Pa 1.26 L/s·m²(Total Area) At +75Pa 0.43 L/s·m²(Opening Joint) At -75Pa 6.89 L/s·m²(Total Area) At -75Pa 2.37 L/s·m²(Opening Joint) At +150Pa 2.24 L/s·m²(Total Area) At +150Pa 0.77 L/s·m²(Opening Joint) At -150Pa 11.66 L/s·m²(Total Area) At -150Pa 4.01 L/s·m²(Opening Joint) Rating: Class 1 PASS	9 Sept. 2025 Test Report No.: AZHK250835
Dimension of Window Frame:		3020 mm (Height) x 3540 mm (Width) x 93 mm (Thickness)					
Dimension of Window Sash:		Operable Sash: 2872 mm (Height) x 810 mm (Width) (4 Pieces)					
Frame Corner Construction Details:		Mechanically assembled: Screw(see testing report for details)					
Hardware:		Name: Handle, Model No.: KS80AL-01, KS80AL-02, Quantity: 4 pieces, Supplier: KERSENBERG, Name: Pulley System, Model No.: KS80AL-03, Quantity: 2 pieces, Supplier: KERSENBERG Name: Load-Bearing Hangers, Model No.: KS80AL-04, Quantity: 4 pieces, Supplier: KERSENBERG Name: Folding Hinges, Model No.: KS80AL-05, Quantity: 32 pieces, Supplier: KERSENBERG					
Drainage:		Size: (Width x Height) 8*30 mm, Spacing: 450mm, Quantity: 9, See Drawings for Details					
Gasket (between the sash and the frame)		Model No.: EP1081, EP1082, EP1083, EP1084, EP1085 Material: EPDM, Supplier: MEIRUN Model No.: 10*15 Wool, Material: Wool, Size: 5*15, Supplier: LIJIALONG					
Thermal break:		Model No.: C14.8, Material: PA66FG25, Supplier: Baiyunyile					
Reinforcement:		None.					
1. This certification excludes installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSI Licence Number: **7708**
 Certification Issue Date: 12 Sept. 2025
 Certification Expiry Date: 19 July 2026
 CSI Schedule Number: CSI Lic 7708-2025-07-S13-R0

Certification Review Date: 4 June 2025
 Next Annual Review Date: 15 June 2026
 CSI Database ID Number: 1000413


 Azma Khan
 Managing Director



<https://register.jasanz.org>



<https://iaf.eu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
 This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.

Certification Solutions International Pty. Ltd. ABN 49 123 368 650 PO Box 904 Fairfield, NSW 1860 Australia, Ph:+61 2 9728 7608
 Email: admin@csi-certification.com Web: www.csi-certification.com


PRODUCT COMPLIANCE SCHEDULE

Meichen High Tech Industries Co., Ltd.

COMPANY ADDRESS: No. 6, Liyuan Street, Dawang High-tech Development Zone, Sihui, Zhaoqing City, Guangdong Province, China

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSI Licence Number may be used.


AS 2047:2014 Windows and external glazed doors in buildings

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Infiltration Rating	Date of Endorsement
	MC80BD-TH	Aluminium Bi-fold Door	Positive - 1500 Pa Negative – 1200 Pa Rating: N5 (General) N4 (Corner window)	2000 Pa Rating: N4 (General) N3 (Corner window)	No water penetration at: 350 Pa for 15 minutes. Rating: N4 (Exposed) N5 (Non-exposed)	At +75Pa 13.4 L/s m² At -75Pa 55.74 L/s m² Rating: High	2025/8/21 Test Report No. AZHK250834
			PASS	PASS	PASS	PASS	
Dimension of Window Frame:		3020 mm (Height) x 3540 mm (Width) x 93 mm (Thickness)					
Dimension of Window Sash:		Operable Sash: 2872 mm (Height) x 810 mm (Width) (4 Pieces)					
Frame Corner Construction Details:		Mechanically assembled: Screw(see testing report for details)					
Hardware:		Name: Handle, Model No.: KS80AL-01, KS80AL-02, Quantity: 4 pieces, Supplier: KERSSENBERG, Name: Pulley System, Model No.: KS80AL-03, Quantity: 2 pieces, Supplier: KERSSENBERG Name: Load-Bearing Hangers, Model No.: KS80AL-04, Quantity: 4 pieces, Supplier: KERSSENBERG Name: Folding Hinges, Model No.: KS80AL-05, Quantity: 32 pieces, Supplier: KERSSENBERG					
Drainage:		Size: (Width x Height) 8*30 mm, Spacing: 450mm, Quantity: 9, See Drawings for Details					
Gasket (between the sash and the frame)		Model No.: EP1081, EP1082, EP1083, EP1084, EP1085 Material: EPDM, Supplier: MEIRUN Model No.: 10*15 Wool, Material: Wool, Size: 5*15, Supplier: LIJIALONG					
Thermal break:		Model No.: C14.8, Material: PA66FG25, Supplier: Baiyunyile					
Reinforcement:		None.					
1. This certification excludes, Section 7 installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSI Licence Number: **7708**
 Certification Issue Date: 12 Sept. 2025
 Certification Expiry Date: 19 July 2026
 CSI Schedule Number: CSI Lic 7708-2025-09-S21-R0

Certification Review Date: 4 June 2025
 Next Annual Review Date: 15 June 2026
 CSI Database ID Number: 1000413


 Azma Khan
 Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
 This document is the property of CSI and must be returned to CSI upon its request. This document may only be reproduced in its entirety.